



Intertek does hereby certify that an independent assessment has been conducted on behalf of

GPS AIR

Certificate Number: ZOZ-90123-2025g

Certification Issued: 14 September 2026

Certificate Valid Until: 28 November 2026

Applicant Address: 3101 Yorkmont Road Suite 400
Charlotte, NC 28208 USA

Industry Category: Appliances & Electronics

Product Details: See Appendix

Conformance Criteria: UL 2998 (3rd Edition, July 10, 2020) clause 6.5, emittance of ozone not exceeding a concentration of 0.005 ppm.

Issuing Office Name & Address: Intertek Testing Services NA, Inc.
4700 Broadmoor Ave SE, Suite 200
Kentwood, MI 49512 USA
Ph: +1-616-656-7401

Faye Ricker
Certification Officer
14 September 2026

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is valid only for the specific product model(s), batch, or lot number(s) listed. It is not transferable to other products, even if they are similar in nature. Intertek reserves the right to revoke or modify this certificate if, for example, it is determined that the information provided was inaccurate, incomplete or if the product(s) are found to be non-compliant with applicable safety standards.



Certificate Appendix

GPS AIR

Certificate Number: ZOZ-90123-2025g

Product Category	Air Cleaners
Product Name(s)	smartIAQ, smartIAQ GridSet
Model Name(s)	SIAQ1 followed by -; followed by DIST1S, DIST1L, DIST2, DIST3, DIST4, PERF or CENT; followed by -; followed by DC or CC; followed by -; followed by BK; followed by -; followed by 120 or UNV., SIAQ2 followed by -; followed by DIST1S or PERF; followed by -; followed by DC or CC; followed by -; followed by BK; followed by -; followed by 48; followed by NC or BMS
Product Restrictions	None